

Certificate of Hazard Assessment Personal Protective Equipment | Electrical

All managers and supervisors must survey the work areas and activities under their control to determine where personal protective equipment, or PPE, may be required.

Instructions

Identify the workplace location. Conduct a walkthrough survey of the workplace and list the tasks or job functions that require PPE. Ensure PPE has an acceptable ANSI rating based on the chart provided on the back of this sheet. Conduct interviews with employees while performing field observations when necessary and complete this form. Sign and date this certificate. The completed certificate should remain on file in your area and additional areas required by your department.

Please note:

When determining if a potential hazard exists, consideration should be given to the following:

- Employee's perception of hazards.
- History of employee complaints or concerns.
- History of injuries or illnesses related to the workplace or job.

Task	Potential hazard	PPE required
Testing energized voltage, 50V-120 Volts AC	Electric shock	Safety glasses, natural fiber long sleeves, Class 0 rubber insulating gloves & leather protectors
Testing energized voltage, 50V- 600 Volts AC	ARC Flash -PPE Category 1 (4 cal/cm ²)	Long sleeve shirt (or jacket) and pants, Safety glasses and face shield, Class 0 rubber insulating gloves and leather protectors
Testing energized voltage, 50V- 600 Volts AC	ARC Flash - PPE Category 2 (8 cal/cm ²)	Arc-rated long sleeve shirt and pants, AR face shield and safety glasses, sock hood/balaclava, Class 0 rubber insulating gloves and leather protectors.
Testing energized voltage, 50V- 600 Volts AC	ARC Flash - PPE Category 3 (25 cal/cm ²)	Arc-rated flash suit jacket and AR pants, Arc Rated flash suit hood, safety glasses, Class 0 rubber insulating gloves and leather protectors.
Testing energized voltage, 50V- 600 Volts AC	ARC Flash - PPE Category 4 (40 cal/cm ²)	Arc-rated flash suit jacket and arc pants, arc-rated flash suit hood, safety glasses, Class 0 rubber insulating gloves and leather protectors.

Observation		
Are employees wearing PPE appropriate to tasks? Yes <input type="checkbox"/> No <input type="checkbox"/>	Is PPE worn and adjusted properly? Yes <input type="checkbox"/> No <input type="checkbox"/>	Is PPE maintained in good condition? Yes <input type="checkbox"/> No <input type="checkbox"/>

If no, describe the corrective action taken:

I _____, certify that the above location has been evaluated for potential hazards and the appropriate PPE, and that training has been performed.

Signature of Assessor: _____ Date: _____

Questions? Contact ASU Environmental Health and Safety at 480-965-1823 or email asuehs@asu.edu.

Revision date 05/8/2024