

**Certificate of Confined Space Hazard Elimination**

Post this form at entrance to space. Do not use for spaces with hazardous atmospheres.

<b>Specific location – CS number, room number, building, address</b>	Date, time valid – less than eight hours:
<b>Specific tasks to be performed in the space</b>	
<b>Hazards identified – Electrical, mechanical, etc.</b>	
<b>How hazards will be eliminated – LOTO outside of space, removal of dangerous equipment following a permitted entry procedure, etc.</b>	
<b>Were methods used to eliminate hazards effective?</b>	
Signature and printed name of <b>confined space safety competent and authorized</b> employee  _____	

If unsure how to proceed, contact EHS at 480-965-1823.

**According to OSHA 1910.146, you must follow these requirements and the space must meet these conditions when classifying a confined space as a non-permit confined space:**

- Certify this documentation with the following:
  - Date.
  - Location of the space. Provide the space's number or by being as specific about physical location as possible.
  - Make the certification available to each entrant, or their authorized representative. At ASU, this is accomplished by posting the form at the site of entry.
  - Signature of the person making the determination. At ASU, this certification is determined by an employee who is trained and competent in the subject of confined space entry and safety.
- Document how you determined the confined space contained no permit-required confined space hazards.
- If you must enter to remove hazards, the space must be treated as a permit-required confined space until hazards have been eliminated.
- The confined space doesn't contain an actual or potentially hazardous atmosphere.
- The confined space doesn't contain hazards capable of causing death or serious physical harm. This includes any recognized health or safety hazards including engulfment in solid or liquid material, electrical shock or moving parts.

**Note:** This certification must be completed every time a permit-required confined space is reclassified as a non-permit space.